


OPERATION

Application of voltage to the input of the timer initiates the OFF time. Upon completion of the OFF time, the relay energizes and the ON time begins. Upon completion of the ON time, the relay de-energizes and the cycle is complete. Reset during or after the time periods is accomplished by removal of the input voltage. The OFF/ON time periods are independently adjustable.







MODEL NUMBER

MODEL NUMBER	TDH		Α			
SUPPLY VOLTAGE						
24 VAC or DC		24				
110/120 VAC or DC		120				
TYPE OF OPERATION						
Knob Adjustable				Κ		
Lock Nut Adjustable				L		
Fixed				F		
ENCLOSURE STYLE						
8-pin octal plug-in					A	
Blade plug-in					В	
DELAY PERIOD						
See page 77 for stand	lard rang	es avail	able			

Example: TDH-120-ALA-300—Delayed interval, 120 Volts AC or DC, both delays are independently adjustable from 3 to 300 seconds, 8-pin octal plug-in, UL Recognized.



Delayed Interval Relay Output

TDH Series

SPECIFICATIONS

F55826

TIMING RANGES

Virtually unlimited. See page 77 for standard ranges available.

DPDT, 10 A @ 2	50 VAC or 24 VDC, resistive;
211 VA @ 120 \	/AC, inductive
Minimum Setting	+0-20%
Maximum Setting	g ±10%;
Y 1% maximum; ı	no first cycle effect
Before Time Out	100 mSEC
After Time Out	50 mSEC
40 mSEC	
24 or 120 VAC o	r VDC, 50/60 Hz; ±10%
ER No	
Yes	
3 watts (app	proximately)
Operate Storage	32° to 131°F (0° to +55°C) -49° to 185°F (-45° to +85°C)
Mechanical Electrical	10 million operations (minimum) 100,000 operations
	@ rated load
	211 VA @ 120 V Minimum Setting Maximum Setting Maximum Setting Maximum Setting Y 1% maximum; I Before Time Out After Time Out 40 mSEC 24 or 120 VAC o ER No Yes 3 watts (app Operate Storage ICY Mechanical

STANDARD DELAY RANGES AVAILABLE

The chart below shows the standard adjustable time delay ranges available. The part number suffix equals the maximum adjustable delay period of the timer. No letters following the suffix number indicates the delay period in seconds; an M indicates minutes; and an H indicates hours.

STANDARD DELAY RANGE CHART

• • • • • • • • •		
PART NUMBER SUFFIX	MINIMUM SETTING	MAXIMUM SETTING
010	0.1 seconds	10 seconds
030	0.3 seconds	30 seconds
060	0.6 seconds	60 seconds
100	1 second	100 seconds
200	2 seconds	200 seconds
300	3 seconds	300 seconds
600	6 seconds	600 seconds
900	9 seconds	900 seconds
30M	18 seconds	30 minutes
60M	36 seconds	60 minutes
90M	54 seconds	90 minutes
2H	1.2 Minutes	2 hours
4H	2.4 Minutes	4 hours
8H	4.8 Minutes	8 hours
12H	7.2 Minutes	12 hours
16H	9.6 Minutes	16 hours
20H	12 Minutes	20 hours
24H	14.4 Minutes	24 hours

Longer delays available upon request. Consult Factory

EXTERNAL RESISTANCE SELECTION

On models specified as having the external resistor adjustability feature, the delay period is set by placing resistance across designated pins or terminals. One meg ohm resistance provides the maximum delay on all models. The minimum delay is obtained by jumping the terminals together.

The resistor or potentiometer chosen should be a 1/4 watt or larger.

To determine the resistor value required for a specific time delay, use the following formula:

 $R_{ext} = (T_{des}/T_{max}) \times 1000$

R_{ext} = Resistance value required to obtain T_{des}(in K ohms)

T_{des} = Desired time delay

T_{max} = Maximum delay period of the timer

Example: Model TDC-120-ARC-300; find the external resistance value required for a 240 second delay:

$$R_{ext} = \frac{240}{300} x 1000 = 800 \text{ K ohms}$$

"FIXED" DELAY OPTION

Most ATC Diversified timers are available with the delay period factory preset ("fixed") for some specified duration. When this option is ordered, the part number should have an "F" in the Type of Operation designation: and the last digits should specify the desired time delay in seconds (S), minutes (M), or hours (H).

Example: TDC 120-AFA-30M—delay-on-operate,120 Volts AC or DC, 8-pin octal plug-in package with a 30 minute fixed delay.

OFF/ON DELAY TIMERS

Included in ATC Diversified's broad line of timers are six (6) models that feature independent OFF/ON delay adjustments. They are TDF, TDH, TDI, TSF, and TSH. Notice in the ordering information section on each of their respective pages the timing range is specified by a three (3) digit suffix. This indicates that both the OFF and ON delay periods have the same timing ranges. Example: TDF-120-ALA-300: Both OFF and ON delay periods are independently adjustable from 3 to 300 seconds.

In the event that two (2) separate delay ranges would be required, the part number is modified to add a slash(/) followed by three (3) more digits. Since the OFF delay(TI) is first in all models, it is specified first in the part number. Example: TDF-120-ALA-12H/30M: the OFF delay is adjustable from 7.2 minutes to 12 hours and the ON delay is adjustable from 18 seconds to 30 minutes.

NOTE: Combinations of various "types of operation" are available: fixed/adjustable, knob/lock nut, etc. Consult factory.

MODEL NUMBER

24 120 240	A			
120				
120				
120				
120				
120				
120				
240				
	D			
		K		
		L		
		F		
		R		
				A
			В	
			С	

NOTE: Not all time delays are available with each option shown above. The specific options for each timer type are described on their respective pages.